

Certificate of Compliance

Certificate Number 050407 - E308649
Report Reference E308649, March 30th, 2007
Issue Date 2007 April 5

Page 1 of 3



Issued to: **BONFIGLIOLI RIDUTTORI SPA**
VIA GIOVANNI XXIII 7/A
I-40012 LIPPO DI CALDERARA (BO) ITALY

This is to certify that representative samples of

Motor constructions for motors
See Addendum for Series

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.



Standard(s) for Safety:

UL 1004 - Electric Motors
CSA C22.2 No. 100-04 - Motors and Generators

Additional Information:

See Addendum for Electrical Ratings

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark,  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada, , and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by: *Mauro Cerioli*
Mauro Cerioli, Associate Project Engineer

Reviewed by: *Maurizio Migliavacca*
Maurizio Migliavacca, Engineering Associate

UL International Italia Srl

UL International Italia Srl

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions in Italy, you may call +39 6410 101.

Certificate of Compliance

Certificate Number 050407 - E308649
Report Reference E308649, March 30th, 2007
Issue Date 2007 April 5

Page 2 of 3



**Underwriters
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

- Motor series BN f/B 27, 44, 56, 63, 71, 80, 90, 100, 112, 132, 160M/L, 180M/L, 200L, f/b two or three digits, f/b additional letters and numbers.
- Motor series BN-EP f/B 63, 71, 80, 90, 100, 112, f/b two or three digits, f/b additional letters and numbers.
- Motor series K f/B 63, 71, f/b two digits, f/b additional letters and numbers.
- Motor series M f/b 0, 05, 1, 2, 3, 4, 5 f/b two digits, f/b additional letters and numbers.
- Motor series M-EP f/B 1, 2, 3 f/b two digits, f/b additional letters and numbers.

Issued by: *Mauro Cerioli*
Mauro Cerioli, Associate Project Engineer

UL International Italia Srl

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL/UL International Italia Srl

Reviewed by: *Maurizio Migliavacca*
Maurizio Migliavacca, Engineering Associate

UL International Italia Srl

Certificate of Compliance

Certificate Number 050407 - E308649

Page 3 of 3

Report Reference E308649, March 30th, 2007

Issue Date 2007 April 5



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

Motor Series	Voltage (Vac)	Frequency (Hz)	Phase (N°)	Max Power (kW)
Series BN	Up to 600	50/60	3	34.0
Series BN-EP	Up to 600	50/60	3	4.80
Series K	Up to 600	50/60	3	0.90
Series M	Up to 600	50/60	3	25.4
Series M-EP	Up to 600	50/60	3	4.80

Issued by: *Mauro Cerioli*
Mauro Cerioli, Associate Project Engineer

Reviewed by: *Maurizio Migliavacca*
Maurizio Migliavacca, Engineering Associate

UL International Italia Srl

UL International Italia Srl

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL/UL International Italia Srl